

SCAFFOLD FALL PROTECTION CHECKLIST

COMPLETE THIS CHECKLIST PRIOR TO USING ANY TYPE OF
SCAFFOLDING.

- ☐ Fall protection required at 10 ft (3.1 m) or higher
- ☐ Supported scaffolds: Guardrails OR PFAS required
- ☐ Suspended scaffolds: Guardrails AND PFAS required
- ☐ Guardrails: 38–45 in, withstand 200 lbs, midrail + toe boards
- ☐ Safe access provided (ladders, stairs, ramps)
- ☐ Scaffold inspected before each shift
- ☐ Take the scaffold out of service if damaged/unstable
- ☐ Platforms clear of clutter and within load ratings
- ☐ Toe boards, debris nets, and tool lanyards (recommended)
- ☐ Written rescue and retrieval plan in place
- ☐ Training required for all scaffold users
- ☐ Inspection logs, scaffold tags, training records on-site